

DEPARTMENT OF PUBLIC HEALTH AND PREVENTIVE MEDICINE

SANITARY CERTIFICATE

(Under the Tamilnadu Education Rules)

Appendix - 3

(Chapter III Rules - 24)

I hereby declare that I have inspected **CASA GRAND INTERNATIONAL SCHOOL BUILDING AND PREMSIES**, located at Survey Nos.473/1A1B and 473/1B, Global Hospital Main Road, Embassy Back, Perumbakkam, Chennai - 600 100, Tambaram Taluk, Punitha Thomaiyar Malai Block, Chengalpet District, on Tuesday, 9th May 2023 and certify

- ❖ That the accommodation provided for each of the several class rooms are sufficient for the minimum number of pupils taught there in and is properly ventilated and lighted.
- ❖ That the building is maintained in substantial repair.
- ❖ That is neat and clean.
- ❖ That the supply of drinking water is wholesome.
- ❖ That the latrine and urinal arrangements are adequate for both sex and good.
- ❖ That in all other necessary aspects the sanitation is good.

Conditions:

- ❖ The School Authority should ban the Cigarette and other Tobacco products in the campus and visible board to be displayed – COTP Act 2003.
- ❖ This certificate is valid for one year from the date of issue.

L.DIS. No: 3688 / S2 /2023

Date : 09.05.2023



Block Health Supervisor
Medavakkam - 600 100
Punitha Thomaiyar Malai Block.

COUNTERSIGNED

DEPUTY DIRECTOR OF HEALTH SERVICES
Chengalpet , Chengalpet District.

To
The Principal / Correspondent
CASA GRAND INTERNATIONAL SCHOOL
Survey Nos.473/1A1B & 473/1B
Global Hospital Main Road
Embassy Back, Perumbakkam
Chennai - 600 100.

For CASAGRAND INTERNATIONAL SCHOOL

Correspondent

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.03/2024

Dated:16/04/2024

It is certified that an inspection team headed by B.Baranidharan.MBBS,DPH,MPH,MBA

(Name of Officers with designation) from Deputy Director Of Health servies,Chengalpattu

District PHED inspected the Casagrand international school-Perumbakkam,Chennai-100(Name &

Address of the school) on 16/04/2024(date of inspection) and on the basis of Water Test

Report (Attached) bearing no VOL/LS/59027 dated 15/04/2024 of VOLVIKA ENVIRO

SYSTEMS (PHED Lab) certified that the Casagrand international school (Name of school)

has safe drinking water facilities for the students and members of staff of the institution.

School is also maintains the hygienic sanitation condition in the school building & the campus

as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 14/04/2025

Signature with Seal:

Name: B.Baranidharan. MBBS, DPA, MPH, MBA.

Designation : Deputy director of Health services.

Name & Address of the Office / Department :

Deputy Director of health services ,Chengalpattu
district

To

Correspondent
Casagrand international
school,Perumbakkam
(Name & Address of the Institution)

TPA
24.4.24



Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



VOLVIKA ENVIRO SYSTEMS

1-A, 7th A-Lane, K.K. Road, Venkatapuram, Ambattur, Chennai - 600 053.
Mobile : 98400 21067, E-mail : volvika2002@yahoo.co.in
SSI REGISTERED

LABORATORY SERVICE DIVISION

TEST REPORT

Order No	: VOL/LS/59027	Cert Date	: 15/04/2024
Name Of The Sample	: M/s.CASA GRAND INETRATIONAL SCHOOL.	Received Date:	13/04/2024
Name Of The Client	: M/s.MAJESTIC ENTERPRISES.	Analysis From:	13/04/2024
Test Required	: Physical/Chemical Analysis Of Water	Analysis To	: 15/04/2024

PHYSIO-CHEMICAL PARAMETERS

S.No	PARAMETERS	RESULTS	Drinking Water As Per IS:10500-2012
01	Physical Examination	Clear	Colourless
02	Appearance after filtration	Clear	Clear
03	Colour as TCU	1.0	2.0
04	Turbidity as NTU	0.1	2.0
05	P ^H at 25° C	6.57	6.5 - 8.5
06	Conductivity at 25° C Micromho/cm	144	1000
07	Total Dissolved Solids mg/l	86	500
08	Total Suspended Solids mg/l	Nil	10
09	Phenolphthalein Alkalinity mg/l as CaCO ₃	Nil	----
10	Methyl Orange Alkalinity mg/l as CaCO ₃	4	----
11	Total Hardness mg/l as CaCO ₃	2	300
12	Calcium Hardness mg/l as CaCO ₃	2	----
13	Magnesium Hardness mg/l as CaCO ₃	Nil	----
14	Carbonate Hardness mg/l as CaCO ₃	2	----
15	Non Carbonate Hardness mg/l as CaCO ₃	4	----
16	Calcium mg/l as Ca	1	75
17	Magnesium mg/l as Mg	Nil	30
18	Chloride mg/l as Cl ⁻	48	250
19	Sulphate mg/l as SO ₄	Nil	200
20	Silica mg/l as SiO ₂	0.2	----
21	Total Iron mg/l as Fe	Nil	0.3


Chemist



Authorised Signatory